



Certificate of Compliance

Certificate: 70184750

Master Contract: 259077

Project: 70203118

Date Issued: 2019-01-28

Issued to: Altenergy Power System Inc.
No.1 Yatai Road
Jiaying, Zhejiang, 314050
CHINA
Attention: Guofeng Jiang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Allen Yao*
Allen Yao

PRODUCTS

CLASS - C531109 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Grid Support Utility Interactive Microinverter, Model QS1200 and QS1, Rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 107.1-16 - General Use Power Supplies

*UL1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision dated February 15, 2018)

*Note: Conformity to UL 1741 (Second Edition, Revision dated February 15, 2018) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547.1-2005(R2011), California Rule 21 and Supplement SA.