



Letter of Attestation

Document: 80030319

Master Contract: 259077

Project: 80030319

Date Issued: January 19, 2020

Issued to: Altenergy Power System Inc.
No.1 Yatai Road
Jiaxing, Zhejiang, 314050
CHINA

Attention: Kevin Lu

*CSA Group hereby confirms that it has completed an evaluation of:
Utility Interactive Microinverter, Model QS1A, Rack mounted.*

*CSA Group hereby attests that the products identified above and described
in test report 80030319 dated January 19, 2020
complies with the following standards/tests, to the extent applicable:*

*CSA-C22.2 No. 107.1-16 - Power Conversion Equipment
*UL Std. No. 1741 - Inverters, Converters, Controllers and Interconnection
System Equipment for Use With Distributed Energy Resources (Second Edition,
Revision dated February 15, 2018)*

**Note: Conformity to UL 1741-Second Edition (February 15, 2018) includes compliance
with applicable requirements of IEEE 1547-2003(R2008), IEEE 1547.1-2005 (R2011)*

Issued by: Rohana Yang

CSA Group